

BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION

IN RE: APPLICATION OF TRANS-ALLEGHENY	:	
INTERSTATE LINE COMPANY FOR	:	
(I) A CERTIFICATE OF PUBLIC CONVENIENCE	:	
TO OFFER, RENDER, FURNISH AND/OR	:	
SUPPLY TRANSMISSION SERVICE IN THE	:	
COMMONWEALTH OF PENNSYLVANIA;	:	
(II) AUTHORIZATION AND CERTIFICATION	:	
TO LOCATE, CONSTRUCT, OPERATE AND	:	Docket Nos. A-110172
MAINTAIN CERTAIN HIGH VOLTAGE ELECTRIC	:	A-110172F0002
TRANSMISSION LINES AND RELATED ELECTRIC	:	A-110172F0003
SUBSTATION FACILITIES; (III) AUTHORITY	:	A-110172F0004
TO EXERCISE THE POWER OF EMINENT	:	G-000721229
DOMAIN FOR THE CONSTRUCTION AND	:	
INSTALLATION OF AERIAL ELECTRIC	:	
TRANSMISSION FACILITIES ALONG THE	:	
PROPOSED TRANSMISSION LINE ROUTES	:	
IN PENNSYLVANIA; (IV) APPROVAL OF AN	:	
EXEMPTION FROM MUNICIPAL ZONING	:	
REGULATION WITH RESPECT TO THE	:	
CONSTRUCTION OF BUILDINGS; AND	:	
(V) APPROVAL OF CERTAIN RELATED	:	
AFFILIATED INTEREST ARRANGEMENTS	:	

REJOINDER TESTIMONY OF LAWRENCE A. HOZEMPA

Re: Reliability Needs and TrAILCo Planning Process

March 19, 2008

REJOINDER TESTIMONY OF LAWRENCE A. HOZEMPA

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. My name is Lawrence A. Hozempa and my business address is 800 Cabin Hill
3 Drive, Greensburg, Pennsylvania.

4

5 Q. HAVE YOU PREVIOUSLY FILED TESTIMONY IN THIS PROCEEDING?

6 A. Yes. I have filed written Direct Testimony on behalf of Trans-Allegheny
7 Interstate Line Company ("TrAILCo"), which has been designated as TrAILCo
8 Statement No. 2. I also filed written Rebuttal Testimony on behalf of TrAILCo,
9 which has been designated as TrAILCo Statement Nos. 2-R and 2-R-1.

10

11 Q. PLEASE DESCRIBE THE PURPOSE OF YOUR REJOINDER TESTIMONY.

12 A. This Rejoinder Testimony addresses various assertions contained in surrebuttal
13 testimony from opponents, concerning the reliability need for the Prexy Facilities
14 and the 502 Junction Facilities, and TrAILCo's planning process. Specifically,
15 my rejoinder addresses surrebuttal filed by Office of Consumer Advocate
16 ("OCA") witness Peter Lanzalotta in OCA Statement No.1-SR and Energy
17 Conservation Council ("ECC") witness George Loehr in ECC Statement SR-1.

1 Q. WILL THE USE OF VARIOUS TERMS IN YOUR REJOINDER TESTIMONY
2 BE CONSISTENT WITH THE DEFINITIONS ASSIGNED TO THOSE TERMS
3 IN THE TABLE OF NOMENCLATURE ATTACHED TO TRAILCO
4 WITNESS FLITMAN'S DIRECT TESTIMONY AS TRAILCO EXHIBIT DEF-
5 1?

6 A. Yes. In addition, I may define other specific terms in my rejoinder.

7

8 Q. ECC AND OCA SURREBUTTAL SUGGEST THAT TRAILCO'S REBUTTAL
9 WITH RESPECT TO POST-2009 REQUIREMENTS, IF IMPORTANT,
10 COULD HAVE BEEN ADDRESSED EARLIER. DO YOU HAVE A
11 RESPONSE?

12 A. Yes. I mentioned these other reliability violations in my rebuttal testimony
13 because the transmission models being used for future analyses, years beyond
14 2009, include the Prexy Facilities. The only way I could thoroughly test Mr.
15 Lanzalotta's proposal from his rebuttal was to remove the Prexy Facilities from
16 these future models and insert Mr. Lanzalotta's proposed facilities in the model.
17 My rebuttal testimony is simply a summarization of my findings.

18

19 I believe this information is relevant because as we conduct transmission planning
20 studies, planned solutions become part of the loadflow model. The current
21 version of the Prexy Facilities proposal was planned in 2001, with an in-service
22 date of July 2011. Since 2001, the Prexy Facilities have been incorporated into
23 our long-range planning model. As we perform our transmission assessments,

1 sensitivity analyses are also conducted on planned solutions to determine if the in-
2 service date is acceptable, needs advanced, or can be delayed as the planning
3 model is updated from year-to-year.

4
5 As more analyses were conducted, it became apparent that the Prexy Facilities
6 will provide significant reliability improvements not only to the transmission
7 system in the Prexy area but also to the surrounding area in future years.
8 However, that does not change or invalidate that the primary reason for the Prexy
9 Facilities is the thermal and voltage reliability violations in the Prexy area. While
10 the proposed solution has reliability benefits beyond the Prexy area, they are
11 secondary benefits and not the primary driver.

12
13 Furthermore, this is not new information. In a response to the first set of
14 interrogatories from the West Penn Power Industrial Intervenors regarding future
15 transmission constraints in the West Penn Power service territory, TrAILCo
16 provided Allegheny Power's 2006 Assessment of Transmission System
17 Performance as supporting data. This response was available to the intervenors in
18 this proceeding in August 2007. The number of reliability violations that will be
19 corrected by the Prexy Facilities in this assessment is far more than the four
20 primary violations in TrAILCo Exhibit LAH-3 that are driving the immediate
21 need.

1 For example, if I need to replace the tires on my car because my existing tires are
2 worn, I will replace my tires. Once I replace my tires, it is likely my gas mileage
3 will improve and my car will handle better. That doesn't mean I am primarily
4 replacing my tires to get better gas mileage or better handling; those are
5 secondary benefits.

6

7 Q. MR. LANZALOTTA ASSERTS THAT, IF A KEY FACTOR WHEN
8 CONSIDERING THE PROJECT'S 138 KV LINES IS THE NUMBER NEEDED
9 TO ADDRESS THE RELIABILITY VIOLATIONS, TRAILCO'S PROPOSED
10 SOLUTION INVOLVES FIVE 138 KV LINES AS OPPOSED TO MR.
11 LANZALOTTA'S FOUR NEW 138 KV LINES. DO YOU HAVE ANY
12 COMMENT?

13 A. Yes. I agree there will be five 138kV lines or circuits constructed from the Prexy
14 substation under the TrAIL proposal. Four of these lines will be constructed on
15 double circuit poles, which means they will only take the same amount of right-
16 of-way as two circuits. Also, the total line mileage of the TrAILCo 138kV lines
17 is approximately 15 miles as opposed to over 63 miles of 138kV lines for Mr.
18 Lanzalotta's proposal, which will also require nearly seven miles of new right-of-
19 way.

1 Q. MR. LANZALOTTA CLAIMS THAT HIS LOAD FLOW STUDIES CONFIRM
2 THAT "T" JUNCTIONS ARE IN FACT THE CAUSE OF MANY
3 RELIABILITY ISSUES. MR. LOEHR CLAIMS THAT ELIMINATING THE
4 "T" JUNCTIONS WILL ADDRESS THE RELIABILITY ISSUES FOR THE
5 COST OF ONLY SIX 138 KV CIRCUIT BREAKERS. DO YOU HAVE A
6 RESPONSE?

7 A. Yes. First of all, let's make the assumption that there are substations at the "T"
8 junctions. For this discussion I'll call the new "T" junction substations Union Jct
9 SS for the substation at Union Junction and Buffalo Jct SS for the substation at
10 Buffalo Junction. I have shown this assumed network configuration on a single-
11 line sketch (TrAILCo Exhibit LAH-6) to show what the Prexy area would look
12 like with these assumed substations at the "T" junctions. Note I grouped the
13 substations in the immediate Prexy area together in the circle titled "Prexy area
14 substations."

15
16 Using this assumed network configuration, the description of the electrical
17 occurrences shown in TrAILCo Exhibit LAH-3 would be slightly different due to
18 the new line names; however, the electrical result would be the same. A modified
19 version of TrAILCo Exhibit LAH-3 is included as TrAILCo Exhibit LAH-7.

20
21 Another way to look at this situation is to picture the Prexy area substations, as
22 shown in TrAILCo Exhibit LAH-6 as a bowl suspended from the ceiling by four
23 bungee cords. The bungee cords represent the four lines shown in TrAILCo

1 Exhibit LAH-6. Load in the Prexy area would be represented by adding weight to
2 the bowl. Voltage problems would be analogous to the bowl sagging to the floor;
3 and thermal loading problems would be analogous to a bungee cord breaking.

4
5 Allow me to use this analogy to describe the Electrical Occurrence 2 in TrAILCo
6 Exhibit LAH-6. Someone comes along and cuts the bungee cord between Buffalo
7 Jct SS and Cecil SS. The bowl will sag a little closer to the ground as the weight
8 shifts to the remaining three bungee cords and they stretch a little more. Then
9 someone else comes along and cuts the bungee cord between Union Jct SS and
10 Peters SS. At this point the bungee cord between Wylie Ridge SS and Smith SS
11 is stretched to the point of breaking and 11 substations in the bowl are touching
12 the floor.

13
14 This argument about installing substations at the “T” junctions is simply a ‘straw
15 man’ to detract from the magnitude of the reliability violations in the Prexy area.
16 If the reliability violations could be addressed by constructing substations at the
17 “T” junctions, TrAILCo would be proposing that as a solution; however, that
18 solution is no solution at all.

19

20 Q. MR. LANZALOTTA AND MR. LOEHR ARGUE THAT THE PREXY
21 FACILITIES WILL PROVIDE TOO MUCH SYSTEM CAPACITY. DO YOU
22 HAVE A RESPONSE?

23 A. Yes. I addressed this issue in my Rebuttal on page 17. However, in view of the

1 continuing challenge to this point by these witnesses, I want to add to what was
2 already stated. The expected life of these facilities is over 40 years. It would not
3 be prudent from a transmission planning perspective to fail to provide adequate
4 capacity for the expected life of the facilities. It is likely that the 500 kV line
5 from 502 Junction to Prexy will be extended some time in the future. Once the
6 line is extended, it will become part of the EHV backbone of the transmission
7 system and will require the same capacity as other EHV backbone facilities.

8

9 Q. MR. LANZALOTTA CONTENDS THAT THE 2009 AND BEYOND
10 OVERLOADING COULD BE ADDRESSED BY ADDING ADDITIONAL 138
11 KV TRANSFORMERS AT THE WYLIE RIDGE SUBSTATION. DO YOU
12 HAVE A RESPONSE?

13 A. Yes. Adding additional transformers at Wylie Ridge Substation will alleviate any
14 capacity problems at Wylie Ridge Substation. It will not, however, address the
15 problems in the Prexy area unless that additional capacity can be made available
16 through the transmission lines into the Prexy area.

17

18 The Prexy area is approximately midway between the 500/138 kV substations
19 Wylie Ridge and Yukon. Since the load in the Prexy area has developed to the
20 level where the existing transmission system is no longer able to serve the area
21 reliably, it is more efficient to install the additional capacity closer to where it is
22 needed, the Prexy area, than to install the capacity at substations further away.

1 Q. MR. LOEHR'S SURREBUTTAL ASSERTS THAT HIS SUGGESTED
2 ALTERNATIVES WOULD SOLVE THE CLAIMED RELIABILITY
3 PROBLEMS AT CONSIDERABLY LOWER COST THAN THE TRAILCO
4 PROJECT. DO YOU HAVE A RESPONSE TO THIS ASSERTION?

5 A. Yes. Several specifics of the weaknesses and failures in Mr. Loehr's suggestions
6 are set forth below. It is very difficult for me to evaluate his suggestions since he
7 has provided literally no details or supporting analysis for his claims. Mr. Loehr
8 has admitted, in response to TrAILCo's Set Seven Interrogatory addressed to him
9 that he did not conduct any load flow studies to establish that any of his
10 alternatives should be considered. He admitted, further, that he did not attempt to
11 calculate either a cost estimate or any construction schedule for any of his
12 alternatives, and that he is not an expert in either area.

13

14 Q. MR. LOEHR ARGUES THAT THE SOLUTION FOR ANY VOLTAGE
15 PROBLEMS IN THE PREXY AREA IS TO INSTALL REACTIVE POWER
16 SOURCES SUCH AS SHUNT CAPACITORS – NOT TO BUILD A 500 KV
17 LINE WHICH, IN MR. LOEHR'S VIEW, IS OVERKILL. DO YOU HAVE A
18 RESPONSE?

19 A. Yes. Mr. Loehr continues to ignore the totality of problems addressed by the
20 proposed facilities. As clearly stated in TrAILCo Exhibit LAH-3, the problems
21 being addressed are related to more than voltage. They also include thermal
22 loading of the 138 kV lines. Three of the four 138 kV lines serving the Prexy area
23 exceed their emergency ratings and overload under certain contingencies. Mr.

1 Loehr's suggested capacitor bank band-aid would not alleviate the overloads on
2 the 138 kV transmission lines at all, which are NERC reliability criteria
3 violations.

4

5 Q. MR. LOEHR REJECTS YOUR TESTIMONY THAT THE PREXY
6 FACILITIES WERE DRIVEN BY RELIABILITY CONSIDERATIONS. MR.
7 LOEHR CLAIMS THAT THE PROJECT IS PURELY ABOUT ECONOMICS
8 AND BRINGING LOW-COST COAL SOURCES TO MARKET. HE ALSO
9 CONTENDS THAT ANY CONGESTION CONCERN IS "ECONOMIC
10 CONGESTION", AND HAS NOTHING TO DO WITH RELIABILITY, AND
11 THAT "TRANSMISSION CONSTRAINED DISPATCH" IS A WAY OF
12 ELIMINATING THE NEED FOR NEW TRANSMISSION LINES WITHOUT
13 VIOLATING RELIABILITY STANDARDS. DO YOU HAVE A RESPONSE?

14 A. Yes. It is clear that Mr. Loehr has not sufficiently reviewed the facts relating to
15 this project. If he had, he would know there are not any "trapped" low-cost coal
16 generating facilities in the area that will be served by the Prexy Facilities.
17 Furthermore, "economic congestion" has not been claimed or alluded to by any
18 TrAILCo witness as a reason justifying the construction of the Prexy Facilities. If
19 the problem was economic congestion then transmission constrained dispatch
20 would only be a solution to relieve the problem if there was generation in the area
21 available for dispatch. Mr. Loehr's incorrect conclusions are based upon flawed
22 assumptions.

1 Q. MR. LOEHR CONTINUES TO CLAIM THAT YOU FAIL TO UNDERSTAND
2 THAT RELIABILITY DEPENDS ON THE RELIABILITY STANDARDS
3 USED AND NOT ON THE *AMOUNT OF TRANSMISSION*. HE
4 CHALLENGES YOUR "WHEEL AND SPOKES" ANALOGY BY
5 SUGGESTING THAT EVEN THOUGH YOU MAKE THE WHEEL
6 STRONGER, IT COULD LEAD TO DRIVING FASTER AND RESULTING IN
7 A MORE DEADLY ACCIDENT. DO YOU HAVE A RESPONSE?

8 A. Yes. Mr. Loehr is making a faulty assumption that PJM and TrAILCo will
9 always push the existing transmission system to its reliability limits. If this was
10 true, the transmission system would constantly need reinforcement; however, the
11 transmission system has been relatively unchanged for nearly 30 years.

12
13 TrAILCo and PJM are planning to the applicable NERC standards. It is now
14 mandatory, not voluntary, that the transmission system meets the NERC
15 reliability standards. Historic data indicates the system is reaching its limits. The
16 transmission system modeling also shows the future reliability of the transmission
17 system cannot be maintained without reinforcement.

18
19 Q. MR. LOEHR DISPUTES THAT THERE ARE NO GENERATORS IN THE
20 AREA WHERE THE VIOLATIONS OCCUR TO RE-DISPATCH, CLAIMS
21 THAT THERE ARE MANY OPTIONS FOR MANUAL SYSTEM
22 ADJUSTMENTS, AND CONTENDS THAT ONCE REDISPATCH WAS
23 REJECTED, NO ONE CONSIDERED ANY MANUAL SYSTEM

1 ADJUSTMENTS OTHER THAN LOAD SHEDDING. MR. LOEHR ALSO
2 CONTINUES TO ARGUE THAT THE LOADING PROBLEMS CITED
3 AREN'T REAL, BUT RESULT SOLELY FROM THE MISAPPLICATION OF
4 THE NERC STANDARDS. DO YOU HAVE ANY FURTHER RESPONSE?

5 A. Yes. Mr. Loehr refers to our response to ECC Interrogatory VII-28 in arguing
6 that generation in the area where violations occur can be re-dispatched. However,
7 only two generators among those listed in the response to Interrogatory ECC-VII-
8 28 are connected to the 138 kV transmission system. Furthermore, those two
9 generators (Elrama Power Station and Mitchell Power Station) are on the other
10 side of Union Junction from the area where the reliability criteria violations are
11 occurring. Electrical Occurrences 2, 3 and 4 are contingencies of the Union
12 Junction line and isolate those two generators from the area.

13
14 It is apparent that Mr. Loehr has not even reviewed a single-line diagram of the
15 transmission system. Otherwise, he would not continue to consider redispatch of
16 these generators a viable option, even though it is not a viable option to alleviate
17 any of the reliability criteria violations.

18
19 It is interesting to note that OCA's witness, Mr. Lanzalotta, who actually
20 conducted a load-flow analysis, proposed construction of four 138 kV lines to
21 resolve the reliability criteria violations. He did not propose manual system
22 adjustments, including any generator redispatch, as a solution to the reliability
23 criteria violations.

1 Q. DO YOU AGREE WITH MR. LOEHR'S ASSERTION THAT IF THE
2 GROUND CLEARANCE ISSUES ON THE MT. STORM-DOUBS LINE
3 WERE CORRECTABLE BY RETENSIONING THE CONDUCTORS, THE
4 INCREASED RATING OF THE LINE WOULD OBLVIATE THE NEED FOR
5 THE 502 JUNCTION-LOUDOUN LINE?

6 A. No. I would first point out that the rejoinder testimony of Mr. Allen shows that
7 retensioning the conductors is not feasible. Additionally, even if the ground
8 clearance issues on this line could be resolved, the reliability issues on this line
9 that have been identified in the transmission planning studies would still exist.

10

11 Mr. Allen's rejoinder testimony indicates the maximum operating temperature of
12 this line, if the line was retensioned, is 90° which would make the emergency
13 rating of the line 2910 MVA. PJM recently completed an analysis incorporating
14 the most recent and up-to-date information in the load flow analysis as ordered by
15 the Virginia State Corporation Commission Hearing Examiner. This analysis
16 indicates the loading on the Mt. Storm-Doubs line under contingency is 3144
17 MVA. This is 121% of the current emergency rating and would be 108% of the
18 emergency rating if the line could be retensioned. The Mt. Storm-Doubs line will
19 continue to be overloaded even if the line could be retensioned. PJM's study also
20 concluded that additional EHV backbone lines will overload as well. This is
21 consistent with the findings in the 2006 and 2007 RTEPs.

1 The overall conclusion is undeniable. The EHV backbone system is critically
2 lacking capacity. A marginal increase on a single line is not the solution. New
3 EHV transmission capacity needs to be constructed to avoid compromising the
4 reliability of the transmission system in the region.

5

6 Q. DOES THIS CONCLUDE YOUR REJOINDER TESTIMONY?

7 A. Yes. However, I reserve the right to provide such additional testimony as may be
8 necessary or appropriate.

Wylie Ridge SS

Union Jct SS



Smith SS

Peters SS



Prexy Area
Substations

Cecil SS

Manifold SS



Buffalo Jct SS

Gordon SS

**TrAIL – Prexy Facilities
Electric Reliability Problems**

	Electrical Occurrence	Electrical Result
1	Outage of Buffalo Junction-Cecil and Wylie Ridge-Smith 138 kV lines.	The Union Junction-Peters 138 kV line exceeds its emergency rating and overloads.
2	Outage of Buffalo Junction-Cecil and Union Junction-Peters 138 kV lines.	The Wylie Ridge-Smith 138 kV line exceeds its emergency rating and overloads. Also, the 138 kV voltage at 11 substations drops below acceptable limits and could lead to a voltage collapse in the area.
3	Outage of Union Junction-Peters and Wylie Ridge-Smith 138 kV lines.	The Gordon-Manifold 138 kV line exceeds its emergency rating and overloads. Also, the 138 kV voltage at 15 substations drops below acceptable limits and could lead to a voltage collapse in the area.
4	Outage of Union Junction-Peters and Gordon-Manifold 138 kV lines.	The 138 kV voltage at 10 substations drops below acceptable limits and could lead to a voltage collapse in the area.