

**PUBLIC SERVICE COMMISSION  
OF WEST VIRGINIA  
CHARLESTON**

**Case No. 07-0508-E-CN**

**TRANS-ALLEGHENY INTERSTATE LINE COMPANY**

**Application of Trans-Allegheny Interstate Line  
Company for a certificate of public convenience  
and necessity under W. Va. Code § 24-2-11a  
authorizing the construction and operation of the  
West Virginia segments of a 500 kV electric  
transmission line and related facilities in Monongalia,  
Preston, Tucker, Grant, Hardy, and Hampshire  
Counties, and for related relief**

**REBUTTAL TESTIMONY OF  
JAY WILLIAMS**

**January 4, 2008**

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. My name is Jay Williams. My business address is Power Delivery Consultants,  
3 Inc. (“PDC”), 28 Lundy Lane, Ballston Lake, New York 12019.

4 Q. WHAT IS YOUR POSITION AT PDC?

5 A. I am employed by and a principal engineer with Power Delivery Consultants, Inc.  
6 (“PDC”). PDC provides engineering and consulting services to electric utilities,  
7 research organizations, merchant power producers, and manufacturers. Our  
8 practice areas include overhead line and underground cable design, power  
9 transformer ratings, and transmission and distribution-related engineering support  
10 for circuit uprates, operating and maintenance, failure investigation, and training.

11 Q. HAVE YOU PREVIOUSLY FILED TESTIMONY IN THIS PROCEEDING?

12 A. No. I have not.

13

14 EDUCATION AND EXPERIENCE

15 Q. PLEASE SUMMARIZE YOUR EDUCATION AND PREVIOUS  
16 PROFESSIONAL EXPERIENCE.

17 A. I earned a Bachelor of Science degree in engineering from Brown University and  
18 an MBA from New York University. I worked as a cable engineer at  
19 Consolidated Edison Company of New York, Inc. (“Con Edison”) from 1965 until  
20 1973, and was in charge of the transmission cable group when Con Edison was

1 installing major amounts of 345-kV cable. I worked at Power Technologies, Inc.  
2 from 1973 until 1992 and was in charge of the cable group when I left in 1992 to  
3 form PDC with another cable specialist. At PDC, I head a group of engineering  
4 professionals, including five engineers whose entire collective workload is spent  
5 on transmission cable systems. I have developed and present several courses each  
6 year on underground power transmission, and have written more than fifty  
7 technical papers, articles, and book sections on underground transmission cables.  
8 I am a Fellow of the Institute of Electrical and Electronics Engineers, Inc.  
9 ("IEEE") and a registered Professional Engineer in New York and Ohio. My  
10 resume is attached to this testimony as TrAILCo Rebuttal Exhibit JW-1.

11 Q. HAVE YOU PREVIOUSLY APPEARED AS A WITNESS BEFORE ANY  
12 OTHER REGULATORY AGENCIES?

13 A. Yes. I testified as an expert witness on behalf of the Vermont Department of  
14 Public Service for the cable crossing at Grand Isle as part of the PV-20 line  
15 application and regarding an application by the Vermont Electric Power Company,  
16 Inc. and Green Mountain Power Company for authority to construct the Northwest  
17 Vermont Reliability Project. I have also testified as a cable expert for several  
18 utilities evaluating underground transmission lines. I assisted Northeast Utilities  
19 as their expert witness on cable systems for major 345 kilovolt ("kV") installations  
20 as part of the Southwest Connecticut Reliability Project.

1 Q. WILL YOU BE USING THE SAME TERMS IN YOUR DIRECT TESTIMONY  
2 AS SET FORTH IN THE TABLE OF NOMENCLATURE ATTACHED TO  
3 THE APPLICATION?

4 A. Yes. In addition, I may define other specific terms in my direct testimony.

5 Q. PLEASE DESCRIBE THE PURPOSE OF YOUR REBUTTAL TESTIMONY.

6 A. My rebuttal testimony addresses and expands upon the observations of Staff  
7 witness William M. Lewis regarding the feasibility of placing TrAIL underground  
8 or, in the alternative, configuring TrAIL as an overhead direct current (“DC”) line.  
9 This rebuttal testimony will also respond to the general assertion in the direct  
10 testimony of Thomas M. Hildebrand that “there is a real possibility” that TrAILCo  
11 would be required to place the line underground in other jurisdictions by detailing  
12 the significant technical and operating impediments to placing TrAIL  
13 underground.

14

15

#### REBUTTAL

16 Q. WOULD YOU SUMMARIZE STAFF WITNESS LEWIS’ DIRECT  
17 TESTIMONY ON THE TOPIC OF PLACING TRAIL UNDERGROUND.

18 A. Mr. Lewis notes that the feasibility of undergrounding an electric transmission line  
19 at the size, length, and capacity of TrAIL poses many questions. He also observes  
20 that there is no underground 500 kV transmission line comparable to TrAIL is

1 currently operating in the United States and goes on to briefly describe the limited  
2 applications of underground transmission conductor at lower voltages in this  
3 country and elsewhere. Mr. Lewis also estimates that the range of costs to place  
4 TrAIL underground would be five times greater than an overhead installation.  
5 Finally, Mr. Lewis briefly summarizes the problems that would be associated with  
6 constructing TrAIL as a direct current (“DC”) line, either underground or  
7 overhead.

8 Q. DO YOU DISAGREE WITH MR. LEWIS’ ASSESSMENT OF THE  
9 FEASIBILITY OF PLACING TRAIL UNDERGROUND?

10 A. No, I do not disagree with Mr. Lewis’ conclusions. I think it is important for the  
11 record in this proceeding, however, to amplify on the many challenges to placing a  
12 transmission line of TrAIL’s intended voltage, capacity, and length underground.

13 Q. IS IT POSSIBLE TO PLACE ALL OR ANY PORTION OF TRAIL  
14 UNDERGROUND?

15 A. I cannot state that it would be impossible to place portions of the TrAIL project  
16 underground. However, as summarized by Mr. Lewis, there are numerous  
17 impediments to placing 500 kV cables underground and the disadvantages of such  
18 an installation, for all practical purposes, make the placement of any portion of the  
19 TrAIL project underground infeasible for the transmission grid reliability purposes  
20 intended for TrAIL.

1 Q. ARE YOU AWARE OF ANY CIRCUMSTANCES IN THE UNITED STATES  
2 OR ELSEWHERE IN WHICH 500 KV CABLES HAVE BEEN PLACED  
3 UNDERGROUND?

4 A. Again, there are no current examples of the installation of 500 kV cables of any  
5 appreciable length in the United States and certainly none at the length of the route  
6 proposed for TrAIL. In fact, the only instance of cables of this voltage being  
7 placed underground of which I am aware in this country is a short length less than  
8 two miles long of 500 kV underground cables that were installed within the  
9 property of Grand Coulee Dam in the 1970s, from the generator transformers to a  
10 switchyard. Following a catastrophic failure and fire soon after installation, the  
11 replacement cables have operated satisfactorily. During that same period, a 500  
12 kV gas-insulated line a few hundred feet long was installed on the West Coast, but  
13 it has since been abandoned. Outside of the United States, 500 kV cables have  
14 been installed underground on a limited basis in utility tunnels or under bridges for  
15 lengths of less than twenty five miles in Japan and Canada. In addition, 500 kV  
16 submarine cables of lengths limited to about 25 miles or less have been installed  
17 between Vancouver, British Columbia and Vancouver Island. As noted by Mr.  
18 Lewis, installations of underground transmission conductor in Europe have not  
19 exceeded 400 kV. The maximum length of any of these lines is less than 25 miles.

1 Q. WHAT ARE SOME OF THE DISADVANTAGES OF PLACING 500 KV  
2 CABLES IN A PROJECT SUCH AS TRAIL UNDERGROUND?

3 A. Beginning with construction-related disadvantages, placing electric cables  
4 underground requires a massive excavation of the entire length of the segments of  
5 right-of-way planned for underground installation, as compared to excavating  
6 material only at tower locations for an overhead line. To accommodate a 500 kV  
7 project with the power transfer capacity required of TrAIL, such an excavation  
8 would be particularly large in width. For example, as I explain below in my  
9 rebuttal testimony, several sets of cables would be required to provide the power  
10 transfer capability of the three-phase overhead circuit planned for TrAIL. These  
11 cables would be spliced together in fifteen hundred foot sections and would be  
12 placed into individual plastic conduits. Each set of cables could require cement  
13 vaults approximately every fifteen hundred feet, at the points of splicing, that  
14 would be approximately 35 feet long by 8 feet in width and height. The extreme  
15 elevation changes along the West Virginia line route will present challenges in  
16 anchoring the cables to prevent damage from their sliding downhill during  
17 operation, in addition to the problems in civil works and cable installation. The  
18 extensive excavation required to place cables underground could also severely  
19 affect streams, wetlands, and other environmentally sensitive areas along a  
20 proposed right-of-way. Finally, as compared to a relatively limited number of

1 access roads that would be required for subsequent maintenance and repair  
2 operations along an overhead right-of-way, permanent roads would be required  
3 along the entire lengths of any underground segments for the line.

4 Q. ARE THERE ELECTRICAL AND OPERATIONAL DISADVANTAGES TO  
5 PLACING 500 kV CABLES UNDERGROUND?

6 A. Yes, there are several. Because they cannot dissipate heat as effectively as  
7 conductors in an above-ground open air configuration, an underground cable is  
8 able to carry far less power than a similarly-sized overhead line. Mr. Lewis  
9 described the necessity of three sets of three underground cables each to provide a  
10 3,400 MVA capacity for TrAIL. My estimate is that perhaps as many as four to  
11 six sets of 500 kV cables (twelve to eighteen individual cables) could be required  
12 to provide the 4,200 MVA power transfer capacity that will be required for TrAIL.  
13 As I stated above, these multiple sets of cables, and required conduit and vaults,  
14 would be a significant contributing factor to the larger excavation that would be  
15 required along the selected right-of-way segment. Additionally, the electrical  
16 capacitance for underground transmission lines is significantly higher as compared  
17 to overhead lines.

18 Q. WOULD YOU BRIEFLY EXPLAIN CAPACITANCE AND WHY IT IS  
19 SIGNIFICANT TO THE ISSUE OF UNDERGROUND TRANSMISSION  
20 LINES?

1 A. Yes. Cable capacitance is an inherent property of all cable systems, and results  
2 from the placing of insulation material between two cylindrical electrodes – the  
3 internal cable conductor and outer cable shielding. Capacitance may cause a  
4 significant increase in steady-state voltages throughout a power system as the  
5 charging current – the amount of current required to charge and discharge the  
6 cable capacitance at a frequency of 60 times per second – flows through inductive  
7 impedances such as transformers. Even without the presence of these  
8 transformers, a phenomenon known as the "Ferranti effect" causes voltage  
9 increases when the cable charging current flows through the power system itself.  
10 The flow of charging current generates heat, reducing the amount of through-  
11 current the cable is capable of carrying. This means that the charging current  
12 required for 500 kV underground cables would consume the entire power transfer  
13 capabilities of any cables greater than sixty miles in length (depending upon the  
14 type of cable), rendering the cables useless. Finally, the cable capacitance  
15 challenges I just described could also cause unacceptably high transient over-  
16 voltage conditions on substation equipment during switching operations,  
17 damaging the equipment and possibly causing costly, long-term outages.

18 Q. DO UNDERGROUND TRANSMISSION LINES PRESENT ANY  
19 RELIABILITY DISADVANTAGES?

1 A. Yes. A significant example is simply the additional time required for unforeseen  
2 events and repairs to an underground facility as compared to overhead lines. A  
3 problem on a 500 kV line placed underground could require as long as a month or  
4 more to locate and repair; such emergencies on an overhead facility can be located  
5 and repaired much more quickly. Repairing a cable failure typically involves  
6 bringing heavy construction equipment to the site (perhaps requiring placing  
7 temporary construction roads to move the equipment so the failure location can be  
8 accessed). If an entire manhole-to-manhole section of XLPE cable is replaced, a  
9 cable reel weighing 60,000 pounds or more must be brought to the site, the  
10 damaged cable removed, new cable installed, and a new splice made at either end.  
11 If a HPFF cable fails, the situation is much worse since large excavations would  
12 be required adjacent to the failure to freeze the dielectric liquid before the pipe can  
13 be cut open and repairs made. There is no experience with 500-kV polyethylene-  
14 insulated cables in the duct-and-manhole system used by U.S. utilities, and no  
15 experience with 500-kV fluid-filled cables whatsoever. Researchers have  
16 expressed concern that there could be a common failure mode such as thermo-  
17 mechanical movement that could result in multiple outages on these systems.  
18 Prolonged outages of the longer durations that could be experienced with an  
19 underground facility would be counterproductive to PJM's designation of the  
20 TrAIL project as a transmission expansion necessary to maintain grid reliability.

1 Q. ARE THERE CABLES AVAILABLE TO THE ELECTRIC INDUSTRY THAT  
2 COULD BE PLACED UNDERGROUND AT THE VOLTAGE LEVEL AND  
3 LENGTH PLANNED FOR TRAIL?

4 A. Three cable types could be considered; again, however, none have been installed  
5 at 500 kV beyond the limited lengths of the installations I described above. The  
6 three possible cable types would be (i) high-pressure fluid-filled (“HPFF”) cables;  
7 (ii) extruded dielectric, cross-linked polyethylene (“XLPE”) cables; and, (iii) self-  
8 contained fluid-filled (“SCFF”) cables. For installation at 500 kV, however, the  
9 HPFF or the XLPE cables would be the most likely candidates. Both types,  
10 however, would present significant construction and operational issues that would  
11 be disadvantageous. SCFF cables are seldom used for installations on land; they  
12 are primarily installed on long alternating current submarine crossings.

13 Q. PLEASE DESCRIBE HPFF CABLES AND ISSUES THIS CABLE TYPE  
14 WOULD PRESENT.

15 A. HPFF cable accounts for most of the limited amount of underground 345 kV  
16 transmission facilities currently in commercial service in the United States, the  
17 longest of which is a seventeen-mile line. Industry-sponsored tests in this country  
18 have demonstrated the technical feasibility of these cables in a 500 kV application,  
19 but there have been no commercial installations of HPFF cables in the United  
20 States at this higher voltage. A previous short, trial installation of HPFF at 500 kV

1 in Japan is not currently in commercial service. HPFF conductors are insulated  
2 with wrapped layers of a laminated paper/plastic tape that are factory impregnated  
3 with a dielectric liquid and shipped to the installation site on large reels. The three  
4 separate phases are then pulled at one time into a previously installed 8.625-inch  
5 (for 345 kV cables) outside diameter, coated and cathodically-protected steel pipe.  
6 500 kV cables would probably require at least a 10.75-inch outside diameter pipe.  
7 The line is filled with a dielectric liquid that is pressurized to 200-250 pounds per  
8 square inch gauge (“psig”). At a minimum, a large pressurizing plant is installed  
9 at each end of the line segment to maintain this pressure while accepting fluid  
10 expansion and contraction. Assuming level terrain along the right-of-way, a  
11 pressurizing plant is installed at each end of the underground line segment to  
12 maintain pressure while accepting fluid expansion and contractions. For a right-  
13 of-way with significant terrain changes such as the preferred route for TrAIL,  
14 however, an HPFF cable system would also be segregated into multiple hydraulic  
15 (pressurizing) sections wherever elevation changes of greater than 300 feet occur  
16 along the right-of-way. The large volumes of dielectric fluids in the cable pipe  
17 (approximately 100,000 gallons for each line of a four to six line installation of a  
18 ten-mile segment) presents the potential for a large release of this fluid into the  
19 environment in the event of a major leak on even one of the cables. The entire  
20 100,000 gallons of fluid could leak from the pipe, in the hypothetical ten-mile

1 segment described above, depending upon the location of a leak and the time  
2 required for utility crews to find and reach that location to plug the leak. HPFF  
3 cables present the issues of reduced power transfer capability, higher electrical  
4 capacitance, and high transient over-voltages I mentioned above, and are  
5 susceptible to outages for both hydraulic and electrical problems. Finally, the  
6 installation of HPFF cables requires special training and, while there are foreign  
7 suppliers, there is only one domestic supplier for these cables, and none of these  
8 foreign or domestic suppliers have ever manufactured commercially-feasible  
9 lengths of 500 kV cables.

10 Q. LIKewise, would you please describe XLPE cable and  
11 identify any issues the possible use of this type of cable  
12 would present?

13 A. XLPE cables are conductors insulated with polyethylene, which is extruded over  
14 the conductors and then cross-linked at high temperatures. A lead, aluminum, or  
15 copper sheath is applied, and the individual conductors are configured as three  
16 XLPE-insulated cables that are pulled into individual plastic ducts in a concrete-  
17 encased duct bank or tunnel. There are only short, splice-free 345-kV XLPE lines  
18 in commercial service in this country for longer than a year (a 2.1 mile long circuit  
19 with splices was energized in 2007), but there are significant lengths totaling more  
20 than 100 miles installed at 330-kV and higher voltages including 500 kV overseas.

1           There are lengths totaling more than 150 miles installed at 230 kV in the United  
2           States, as well. However, no XLPE cable has been installed at 500 kV in the  
3           United States and the limited experience elsewhere has been in utility tunnels and  
4           not in an underground installation. The manufacture and installation of XLPE  
5           cable requires extremely high levels of quality control due to the high sensitivity  
6           of dielectric materials to contaminants and voids. XLPE cables above 230 kV are  
7           available only from foreign suppliers and these cables also require special skills  
8           and equipment for splicing during installation or for repairs. The lack of domestic  
9           suppliers and the special skill requirements, while not necessarily prohibitive to  
10          the initial installation of an underground facility, are factors that can contribute to  
11          the relatively longer duration of outage repairs on underground cables if  
12          replacement cables must be shipped from overseas locations and the necessary  
13          skilled labor must be located and brought to the outage site.

14    Q.    PLEASE DESCRIBE THE CONFIGURATION OF FACILITIES THAT  
15           WOULD BE REQUIRED TO PLACE EVEN A SEGMENT OF TRAIL  
16           UNDERGROUND.

17    A.    First, a dead-end type transmission structure would be required at each end of an  
18           underground line segment. Transition stations would also be required at each end  
19           of the underground segment; one station to transition the overhead facility into  
20           underground and the other station to transition back to an overhead facility. The

1 transition stations would be fenced areas, much like a traditional substation, with  
2 dimensions of approximately 160 by 320 feet. Each station would have three  
3 cable terminations for each line – 12 to 18 terminations in total, each ten or so feet  
4 tall, on substation-type structures with bases ten feet or more above the ground.  
5 Flexible conductors would be required to drop down from the overhead  
6 conductors to the cable terminations. Additional equipment within each transition  
7 station would include switches, surge arrestors, equipment for communicating  
8 with transmission control rooms, including relaying and alarms, and any circuit  
9 breakers determined to be necessary. This would be repeated at each end of each  
10 segment of the line to be placed underground. For HPPF cable systems,  
11 pressurizing plants with pumps, controls, alarms, and a large storage tank would  
12 be required at each end of an underground segment.

13 Q. YOU INDICATED ABOVE THAT THE CABLES REQUIRE SPECIAL  
14 SPLICING. WOULD YOU PLEASE PROVIDE SOME ADDITIONAL  
15 DETAIL ABOUT THIS PROCESS?

16 A. Yes. The individual cables would be provided in lengths of no more than  
17 approximately 1,500 feet for XLPE-insulated cables, and perhaps 2,000 feet for  
18 HPPF cables, on large reels that may weigh as much as 60,000 pounds or even  
19 more. Consequently, splicing by factory or factory-trained splicing crews is a  
20 significant component of the construction of an underground transmission line.

1 This splicing process requires a “clean room” environment and can take up to ten  
2 days for each individual splice. Because between four and six three-conductor  
3 lines would be required, this would mean between 12 and 18 splicing procedures  
4 would be necessary for every fifteen hundred foot length of the planned  
5 underground segment and would require the cement vaults I described earlier. Mr.  
6 Lewis referred to these vaults as manholes and estimated that the West Virginia  
7 segment of TrAIL placed underground would require 405 of these underground  
8 structures. This complex process not only adds significantly to the length of time  
9 for constructing underground facilities, and as mentioned earlier it is a principal  
10 contributing factor to the relatively long outage periods that would result during an  
11 unforeseen event on an underground line segment. As a comparison, bare  
12 overhead transmission conductors are typically shipped in reel lengths of between  
13 16,000 to 30,000 feet, depending on the size of conductor, and an overhead  
14 conductor splice typically takes one worker less than an hour to complete.

15 Q. REGARDING MR. HILDEBRAND'S TESTIMONY, DO YOU BELIEVE THAT  
16 SUPERCONDUCTING CABLES WOULD BE SUITABLE FOR TRAIL?

17 A. No. Although SuperPower and others have installed short lengths of  
18 superconducting cables as demonstration projects, there is no experience with  
19 cables anywhere near the length, voltage, and power transfer requirements of  
20 TrAIL. It will be many years before utilities even consider superconducting cables

1 at lower transmission voltages as a commercial product suitable for integrating  
2 into the utility's transmission system.

3 Q. WOULD YOU PLEASE SUMMARIZE WHY, IN YOUR PROFESSIONAL  
4 OPINION, IT WOULD BE INFEASIBLE TO PLACE ANY PORTION OF THE  
5 TRAIL PROJECT UNDERGROUND?

6 A. I indicated at the start of my rebuttal testimony that, while it may be technically  
7 possible to place segments of TrAIL underground, the significant construction and  
8 operational challenges I have detailed above, in my opinion, make the placement  
9 of any portion of TrAIL underground infeasible. The significantly longer time  
10 periods that would be required to respond to unforeseen outages on an  
11 underground segment would largely, if not completely, negate TrAIL's intended  
12 purpose for transmission grid reinforcement and reliability enhancement. Because  
13 there is no commercial service experience with HPFF cables at voltage levels of  
14 500 kV or with XLPE cables in an underground environment such as for TrAIL,  
15 any segment of the line placed underground would, for all intents and purposes, be  
16 the equivalent of a research and development demonstration project for the  
17 commercial feasibility of 500 kV underground transmission facilities. In my  
18 professional opinion, such an outcome would be particularly imprudent for a new  
19 high-voltage transmission facility that is intended to maintain transmission grid  
20 reliability.

1 Q. DO YOU ALSO AGREE WITH MR. LEWIS' CONCLUSIONS REGARDING  
2 THE CONSTRUCTION OF TRAIL AS A DC TRANSMISSION LINE?

3 A. Yes, I do. Mr. Lewis notes that many of the same concerns that are posed by the  
4 construction of TrAIL as an underground alternating current ("AC") facility  
5 remain if TrAIL were to be placed underground as a DC line. I agree with his  
6 assessment that the necessary conversion stations to accommodate AC/DC  
7 interconnections are costlier to construct and maintain and that, for both overhead  
8 and underground applications, these conversion stations have not demonstrated the  
9 same level of reliability as continuous AC circuits.

10 Q. DOES THIS CONCLUDE YOUR REBUTTAL TESTIMONY?

11 A. Yes, it does.